

# Grounding System Check Checklist

## Project / Location Information

Project Name		Date	
Location		Inspection By	

## Checklist

No.	Inspection Item	Check	Remarks
1	Grounding conductor size and type are appropriate		
2	Connections are secure and corrosion-free		
3	All metallic parts are bonded to the grounding system		
4	Grounding rod properly installed and accessible		
5	Ground resistance tested and within acceptable limits		
6	Connections are labeled where necessary		
7	No physical damage to grounding system components		
8	All enclosure doors and panels bonded		

## Notes

--

## Inspector's Signature

	Date	
--	------	--