

ADA Compliance Checklist - Accessible Accommodation

Accessible Parking

☐ Accessible parking spaces provided ☐ Van-accessible spaces available ☐ Parking located close to accessible entrance

Accessible Entrance

☐ At least one accessible entrance without steps ☐ Door openings at least 32 inches wide ☐ Door hardware operable with one hand

Common Areas

☐ Accessible route throughout common areas ☐ Hallways and pathways at least 36 inches wide ☐ Elevators usable and accessible

Guest Rooms

☐ Accessible guest rooms available ☐ Adequate maneuvering space in rooms ☐ Accessible controls (light, thermostat)

Bathrooms

☐ Roll-in shower or accessible tub ☐ Grab bars installed ☐ Accessible sink and faucet ☐ Toilet height accessible

Communication Features

☐ Visual and audible fire alarms ☐ TTY available ☐ Assistive listening devices upon request

Other Notes

--