

Indoor Air Quality Check Log

Date:

Location/Room:

Parameter	Measured Value	Unit	Acceptable Range	Comments
Temperature		°C	20 – 24	
Humidity		%	30 – 60	
CO ₂		ppm	< 1000	
PM2.5		µg/m ³	< 12	
PM10		µg/m ³	< 50	
VOC		ppb	< 500	

Inspector Name:

Additional Notes: